



## Enhancement of Power System Stability Using Fuzzy Logic Controller

*Tejaswita Khobaragade and Amol Barve*

*Department of Electrical and Electronics Engineering,  
LNCT, Bhopal, (MP)*

*(Received 30 October, 2012, Accepted 16, November, 2012)*

**ABSTRACT:** This work includes work on the development of a fuzzy logic power system stabilizer to enhance the damping of generator oscillations. In order to accomplish a stability enhancement, speed deviation ( $\Delta\omega$ ) and acceleration ( $\Delta\omega'$ ) of the rotor synchronous generator were taken as the input to the fuzzy logic controller. These variables take significant effects on damping the generator shaft mechanical oscillations. The stabilizing signals were computed using the fuzzy membership function depending on these variables.

The performance of the fuzzy logic power system stabilizer was compared with the conventional power system stabilizer and without power system stabilizer. To achieve good damping characteristics over a wide range of operating conditions, speed deviation and acceleration of a synchronous machine are chosen as the input.

Signal to the stabilizers. The stabilizing signal is determined from certain rules for rule-based power system stabilizer. For fuzzy logic based power system stabilizer, the supplementary stabilizing signal is determined according to the fuzzy membership function depending on the speed and acceleration states of the generator. The simulation result shows that the proposed fuzzy logic based power system stabilizer is superior to rule-based stabilizer due to its lower computation burden and robust performance.

### I. INTRODUCTION

The electrical energy has become the major form of energy for end use consumption in today's world. There is always a need of making electrical energy generation and transmission, both more economical reliable [9]. The voltage throughout the system are also controlled to be within  $\pm 5\%$  of their rated values by automatic voltage regulators acting on the generator field exciters, and by the sources of reactive power in the network.

For proper operation, this large integrated system requires a stable operating condition. The power system is a dynamic system. It is constantly being subjected to small disturbances, which cause the generators relative angles to change. For the interconnected system to be able to supply the load power demand when the transients caused by disturbance die out, a newer acceptable steady state operating condition is reached. That is, the power system must be stable. It is important that these disturbances do not drive the system to an unstable condition [1].

### II. POWER SYSTEM MODELING

**Park's Model.** A great simplification in the mathematical description of the synchronous machine is obtained if a certain transformation of variable is performed.

The transformation used is usually called Park's transformation. It defines a new set of stator variables such as current, voltage, or flux linkages in terms of the actual winding variables on three axes. One along the direct axis of the rotor field winding, called the direct axis; a second along the neutral axis of the field winding, called the quadrature axis; and the third on a secondary axis.

The Park's transformation  $P$  is defined as

$$P = \frac{1}{\sqrt{2/3}} \begin{bmatrix} 1/\sqrt{2} & 1/\sqrt{2} & 1/\sqrt{2} \\ \cos \theta & \cos(\theta - 2\pi/3) & \cos(\theta + 2\pi/3) \\ \sin \theta & \sin(\theta - 2\pi/3) & \sin(\theta + 2\pi/3) \end{bmatrix}$$

The inverse may be computed to be

$$P^{-1} = \begin{bmatrix} 1/\sqrt{2} & \cos \theta & \sin \theta \\ 1/\sqrt{2} & \cos(\theta - 2\pi/3) & \sin(\theta - 2\pi/3) \\ 1/\sqrt{2} & \cos(\theta + 2\pi/3) & \sin(\theta + 2\pi/3) \end{bmatrix}$$

**Two – Axis Model.** In this model the axis d and orthogonal axis q are represented only. Usually one machine is chosen to be the reference frame and a set of machine linearized equation is used in simulation. The state variable may be chosen as  $x^t = [ E'_q, E'_d, E_{fd} ]$ . A linearized system network equations must be provided in the form  $i = f( E'_q, E'_d, )$  [3].


**Hiffron- Phillips Model.** A detailed exploration of the Hiffron-Phillips model is presented as follow:

*A. The Acceleration Equations*


In the case of the classical generator model, the acceleration equations are

$$\begin{aligned} \ddot{\delta} &= \frac{1}{2H} (T_m - T_e - KD\dot{\delta}) \\ \dot{\delta} &= \omega - \omega_r \end{aligned}$$

Where  $\omega_r = 2\pi f_0$  elect rad/s. In the case, the rotor angle  $\delta$  is the angle ( in elect rad) by which the q axis needs the references  $E_B$ . For the single machine connected to an infinite bus shown in Fig. 1. The rotor angle  $\delta$  is the sum of the internal angle  $\delta_i$  and the angle by which  $E_t$  leads  $E_B$  as in Fig. 2.



**Fig. 1.** Single machine connected to an infinite bus.



**Fig. 2.** Vector diagram of single machine connected to an infinite bus.

**III. BASIC CONCEPT**

Unstable inter-area oscillations have been encountered in the last two decades by electrical power utilities throughout the world. In general, the unstable oscillations are involved in power systems, or areas within a power system, which are weakly interconnected. The following occurrence of the inter-area mode instability and their dates are documented in published papers [2].

These occurrences are summarized as follows:

- Mid –content Area Power Pool (MAPP) 1972
- Western U.S. (WSCC) 1978
- Western Australia 1982
- Taiwan 1984
- Southern Brazil 1985
- Ontario Hydra 1985

In this chapter the basic concept for analysis of the system state space model are explored with focusing on the information useful in design of controllers for damping modes of oscillations.

*A. Eigen Values*

A linear dynamic system can be modeled in state space in the form [19, 20].

$$\dot{x} = Ax + Bu$$

$$y = Cx + Du$$

$$x = (sI-A)^{-1} [ x(0) + Bu ] = \frac{Adj (sI-A) [x(0) + Bu]}{Det(sI-A)}$$

*B. Eigen Vectors*

For each Eigen value  $\lambda_i$ , there is a column vector  $t_i$  which satisfies

$$At_i = \lambda_i t_i$$

The vector  $t_i$  is called the right Eigenvector of “A” associated with  $\lambda_i$ . Similarly, There exist a row vector  $v_i$  which satisfies

$$v_i A = \lambda_i v_i$$

This vector  $v_i$  is called the left Eigenvector of “A” associated with  $\lambda_i$ . Also, if “A” is symmetric, then

$$v_i = t_i^T$$

*C. Diagonalization of “A” Matrix*

Diagonalization of the state matrix A is possible if it has a set of distinct Eigen values. Also the set of state variables can be transformed to another set of state variables via a linear transformation with the set of Eigen values being invariant. These are two useful properties of the state space model for the definition of modes and to compute the system response [4].

*D. Mode Controllability*

If the magnitude of a particular mode of the system is completely unaffected by a particular input, this system is said to be uncontrollable. In the uncontrollable system at least one of the row vector  $b_i$ , i.e., at least one row of the matrix  $T^{-1} B$  is zero. This would imply for such modes

$$z_i(t) = e^{it} z_i(0)$$

*E. Mode Observability*

In a similar way the measured output of a system may contain no contribution from a particular mode. The output is given by

$$y(t) = C x(t) + D u(t)$$

In terms of the modes, using the output is

$$y(t) = C T Z(t) + D u(t)$$

*F. Participation Matrix*

In controlling an unstable mode, it is essential to determine the states of the system, which strongly influence the mode to be controlled. Although Eigenvectors give the disturbance of a mode through the system, they depend on units and scaling of the state variable and cannot be used for comparison of states due to non-uniqueness and scaling problems [4].

**IV. METHOD OF DAMPING CONTROLLERS**

*A. Conventional Controllers*

Lead-lag or PID controllers are the result of conventional control theory (i.e. phase and gain margins, root locus....). These controllers are used for the last three decades and still have the leading hand in the real world of PSSs. They can be designed off-line tuned after the installation.

*B. Modern Control Theory*

Optimal, adaptive and pole placement controllers are the resultant controls from modern control theory. They give the desired stabilized response with the

stability margin as required. Due to construction of power systems (i.e. the distances, the extensive numbers of variables.....) they always have problems in the real power system world, as they depend on extensive number of feedback signals [5].

*C. Optimal control Theory*

The principle for optimal control is to minimize saturate cost function which is called the performance index. The design quadratic optimal controller based on such quadratic performance indexes boils down to the determination of the elements of the matrix feedback gain matrix “K”

*D. Adaptive Controllers*

The need of a controller with changes its parameters to give the desired performance while the operating condition change is a goal for several decades. This will avoid the need of investigation of the exact mathematical model. The self tuning controller is used to evaluate the matrices and viability of such a controller [5]. A self tuning controller is a digital adaptive controller which can change the controller’s parameters continuously the operating condition in real time and modified parameter accordingly.

*E. Pole Placement techniques*

Let the system complex Eigen value  $\sigma$  is to be shifted to a new location in the s-plane  $\sigma_0$ . The new location is chosen to satisfy a specified damping ration. It also must satisfy the characteristic equation of the closed loop system, i.e.

$$H(\sigma) = \frac{-1}{G(\sigma)}$$

$$|H(\sigma)| = \frac{-1}{G(\sigma)}$$

*F. Inter- Area Oscillations*

The problem of Inter- Area is a result of power inters change between generating units in power system which are interconnected by a relatively weak transition links.

Inter- Area can be initiated by a small disturbance, such as a change in load or in generation. These types of disturbance occur continuously in power system i.e., a power system with an unstable in Inter- Area mode is impossible to operate.

**V. FUZZY LOGIC CONTROLLER**

*A. Fuzzy logic Theory*

Fuzzy logic is a kind of logic is using graded and quantified statement rather than once that are strictly

true or false. The results of fuzzy reasoning are not definite as those derived by strict logic. The fuzzy sets allow objects to have grades of membership from 0 to 1. These sets are represented by linguistic variables, which are ordinary language terms. They are used to represent a particular fuzzy set in a given problem, such as “large”, “medium” and “small”.

*B. Fuzzy Set Definition*

Let U be a collection of objects denoted generically by {u}, which could be discrete or continuous. U is called the universe of discourse and u represents the generic elements of U [11].

A fuzzy set F in a universe of discourse U is characterized by a membership function  $\mu_r$  which takes values in the interval [0, 1]. A fuzzy set may be viewed as a generalization of the concept of an ordinary set that its membership function only takes two values {0,1}. Thus, a fuzzy set F in U may be represent as a set of ordered pairs of a generic elements u and its grade of membership function:

$$F = \sum_{i=1}^n \mu_F(u_i) / u_i$$

*C. Fuzzification Operator*

A Fuzzification Operator has the effect of transforming crisp data into fuzzy sets.

Symbolically,

$$x = \text{fuzzifier}(x_o)$$

where  $x_o$  is a crisp input value from a process, x is a fuzzy set, and fuzzifier represent a fuzzification operator.

*D. Compositional Operator*

To infer the output z from the given process states x,y and the fuzzy relation R. The sup-star compositional rule of inference is applied

$$z = y \circ (x \circ R)$$

Where o is the sup-star composition

*E. Defuzzification Operator*

The output of the inference process so far is a fuzzy set, specifying a possibility distribution of control action. In the in-line control, a non-fuzzy (crisp) control action is usually required. Consequently, one most defuzzify the fuzzy control action (output) inferred from the

$$z_o = \text{defuzzifier}(z)$$

Where  $z_o$  is the non-fuzzy control output and defuzzifier is the defuzzification operator.

**VI. PROPOSED CONTROLLER**

A simple fuzzy controller based on the experience can damp only local modes. To damp both local and inter-area modes of oscillation, the experience is difficult to be obtained. So, the design process needs a systematic method for obtaining the rule base and the domain ranges. The proposed solution of this problem is that is a fuzzy controller is to be developed based on the optimal control theory. This is capable to obtain a near optimal fuzzy controller that is characterized by its systematic nature in design [6].

*A. Choice of Process State and Control Output*

A first step is to choose the correct input signals to the fuzzy logic control stabilizer. For this controller a choice of state variables representing the contents of the rule-antecedent (If-part of a rule) is selected amongst

1. Generator speed deviation signal.
2. Generator speed deviation change signal.

The control output signal (process input) variable represent the contents of the rule-consequent (then-part of the rule) Fig. 3. This control output is denoted by  $U_{pss}$  (The damping signal which is fed into the reference voltage summing point).

**Normalization.** Normalization performs a scale transformation and its also called input normalization. It maps the physical values of the current process state variables into a normalized universe of discourse (normalized domain). It also maps the normalized value of control output variable onto its physical domain (output demoralization). For this controller a normalization is got by dividing each crisp input on the upper boundary value for the associated universe [12].

**Fuzzification.** Fuzzification is related to the vagueness and imprecision in a natural language. It is a subjective valuation, which transforms a measurement into a valuation of a subjective value. Hence, It could be defined as a mapping from an observed input space to fuzzy sets in creation input universe of discourse. Fuzzification plays an important role in dealing, with uncertain information, which might be objective or subjective in nature.

*B. The generator speed deviation is classified into:*

{negative big (w\_nb); negative medium (w\_nm); negative small (w\_ns); zero (w\_z);

Positive small (w\_ps); positive medium (w\_pm); positive big (w\_pb)}.

The generator speed deviation change is classified into:

{negative big (dw\_nb); negative medium (dw\_nm); negative small (dw\_ns); zero (dw\_z);

Positive small (dw\_ps); positive medium (dw\_pm); positive big (dw\_pb)}.

C. The output of fuzzy controller is classified into:

{negative big (u\_nb); negative medium (u\_nm); negative small (u\_ns); zero (u\_z);

Positive small (u\_ps); positive medium (u\_pm); positive big (u\_pb)}.




Fig. 4. Blocker diagram shows the exciter and the proposed.




Fig. 3. The stages of the proposed FLC.




Fig. 5. Membership functions normalized in one common universe (nb: negative big, nm: negative medium, ns: negative small, z: zero, ps: positive small, pm: positive medium, pb: positive big).

After this classification, the fuzzification module can be applied. By conversion of a point-wise (crisp) and current value of a process state variable (generator speed deviation signal and generator speed deviation change signal) into their associated fuzzy sets, this will make it compatible with the fuzzy set representation of the process state variable in the rule-antecedents. Each crisp input (either generator speed deviation signal or generator or speed deviation change signal) has seven tuples denoted by : {classified fuzzy set and its membership function value.}


For example if normalized generator speed deviation = -0.2 then it has seven tuples as follows:

- (w\_nb,0)
- (w\_nm,0)
- (w\_ns,0.8)
- (w\_z,0.2)
- (w\_ps,0)
- (w\_pm,0)
- (w\_pb,0)

Then each crisp input can be fuzzified to obtain its membership values through the associated seven classes in the normalized universe of discourse.

*D. Fuzzy Controller Simulation*

In this section the simulation algorithm of the proposed fuzzy controller is discussed. For each time step in the system main simulation, a calculation of the generator speed deviation signal and generator speed deviation change in signal is made. This is achieved by getting the value of the state variable in the state matrix “A” which equal to the generator speed deviation. The value of generator speed deviation signal from the previous generator speed deviation signal. The associated membership values for each normalization input are calculated. Then applying the max-min method inference method to get the control output in fuzzy values. These fuzzy values can be converted to a crisp value by COG method. The signal of the controller is the damping signal that is fed into the reference voltage summing point to get the next state values [16].



**Fig. 6.** Calculation of the membership values due to a certain input.

**VII. BASE STUDY**

For the integrated system both local modes and inter-area modes appear.

Then, a simple fuzzy controller based on the experience can only damp local modes.

Therefore, the solution of this problem is that a fuzzy controller is to be developed based on the optimal control theory. The optimal controller depends on feeding back signals from all states of the system, to damp both local and inter-area modes. The resultant fuzzy controller should approach the optimal as compared with the optimal controller results for damping small disturbance through many operating conditions. So a near-optimal fuzzy stabilizer for damping both local modes and inter-area modes is developed [17].

*E. Fuzzy Logic Controller for Damping Oscillation in a Simple Power System*

In this section, it is decided to apply a fuzzy logic controller for a synchronous machine to an infinite bus system. The synchronous machine as represented in[1]. is assumed to have a thyristor-type excitation system and connected through a transformer and a transmission line to an infinite bus. The system data is found in [1] and Appendix (B). To discuss the small signal stability problem, the nonlinear equations representing the system must be linearized.

**VIII. RESULT AND DISCUSSION**

The performance of single machine infinite bus system with lead-lag PSS and fuzzy PSS has been studied in SIMULINK environment. The fuzzy stabilizer has been modeled in *fis* editor of *matlab*. The SIMULINK model of the system with fuzzy PSS. Corresponding to the system data specified in Appendix, the K-coefficients are calculated as K1 = 0.7636, K2 = 0.8644, K3 = 0.3231, K4 = 1.4189, K5 = -0.1463, K6 = 0.4167. The scaling factors associated with input and output variables are tuned and taken as Kin1 = 1.8, Kin2 = 29.58, Kout =1.05. For such constants, which are in Fig. 7., the performance has been studied under different conditions. Although the stability problem in practical power system is mainly due to poor damping, the constant K5 has important bearing on system performance. Its value normally found to be negative for high reactance and high power output, a practical situation. The K5 can have positive value for low reactance and low power output. Therefore, the performance is studied for small 0.05 p.u. change in input for both K5 negative (-0.1463) and K5 positive (0.1463) and response characteristics.




Fig. 7. SIMULINK model with fuzzy logic based PSS.




Fig. 10. Angular speed for a 0.05pu change in mechanical input with K5 Positive.




Fig. 8. SIMULINK model with Lead lag PSS.

As shown in Fig. 9 and Fig. 10 the oscillations are more pronounced in case of inputs and outputs having trapezoidal membership functions for K5 positive and the system become stable after a long time of 9 seconds approximately. With K5 negative, generally the practical case, the performance characteristics are shown in Fig. 9 and Fig. 10. The unstable behavior is resulted if the trapezoidal membership function is used with negative value of K5. As evident from Fig. 9 and Fig. 10, the performance with trapezoidal membership functions is unsatisfactory and thus this membership function is not suited for the PSS design. The performance of lead-lag PSS and PSS using gaussian and triangular membership functions is comparable and the system becomes stable after in nearly 7 seconds.



Fig. 9. Angular position for a 0.05pu change in mechanical input with K5 Positive.




Fig. 11. Angular position for a 0.05pu change in mechanical input with K5 negative.




Fig. 12. Angular speed for a 0.05pu change in mechanical input with K5 negative.




Fig. 14. Angular position for a 0.05pu change in mechanical input with K5 negative with the change in spread of Gaussian membership function.




Fig. 13. Angular speed for a 0.05pu change in mechanical input with K5 negative with the change in spread of Gaussian membership function.




Fig. 15. FIS Editor.

The response for different operating conditions using triangular membership functions is investigated for negative value of K5 and the performance characteristics are shown in Fig. 14 for 10%, 20%, 30% and 45% change in mechanical input. With triangular membership functions, the response is coming out to be stable in all the cases with very less oscillations thus enhancing the stability of a system. The performance of FPSS with triangular membership function is superior in comparison to the performance with other PSS [15].




Fig. 16. Rule Viewer.

## IX. CONCLUSION

### A. Summary of Results

The target of the developed work is the damping of oscillations related to power system using a controller based on fuzzy logic theory. On two systems, single machine to infinite bus system and 4-machine test system, the proposed controller provide a more robust control over a large excursion of the operating points various and optimal controller and lead lag stabilizer most of the previous control method either are not working sufficiently under whole range of operating condition or they need complicated calculation as they require the exact model methodology to site the proposed controller doesn't depend on the Eigen analysis approach model Analysis approach is the usually used techniques for getting the controller result the methodology here is from the time response of the system due to various operating condition are proposed and tested. The resulting of the proposed controller is the increased damping and stability of both local and inter-area modes. The proposed controller showed its effectiveness through-out a board range of the test system operating conditions.

### B. Conclusion

- 1) An effective controller based on fuzzy logic theory for the damping both local inter-area modes is developed.
- 2) A systematic generation of fuzzy logic controller rule base and I/O domain range is investigated and tested.
- 3) No need to transfer measurements between areas as each controller has its input from its area.
- 4) Fuzzy logic controllers can be effective in large-scales systems.

### C. Future Work

The future of this particular research topic has many different facts this include, using of different input signal for a fuzzy logic controller and investigation about non-linear loading.

**Other PSS Input Signals.** Current resource has focused on rotor speed as a control variable; a frequency-input controller ( f) must be investigated as-well. However, it has been found that frequency is highly sensitive to the strength of the transmission system, that is, more sensitive when the system is weaker which may off-set the controller action of the electrical torque of the machine other limitation include the presence of sudden phase shift following rapid transient and large noise include by industrial loads. On the other hand, the frequency signal is

more sensitive to inter-area oscillations then the speed signal. Also, using of power-input signal ( P) as the input to the fuzzy controller as well. However this signal was prove to be more effective for damping the inter-area mode efficiently but the local modes the rotor speed is efficient, so trade off may be appeared [2].

**Non-linear Loading.** In this research, the simulations for the two systems are done by an assumption that is the loads are static. Then each load can be represented by constant shunt impedance. However the future work may study the effect of non-linear loading upon the power system modes and the controller.

## REFERENCES

- [1]. A .Ghosh, G.Ledwich, O.P.Malik and G.S.Hope, "Power System Stabilizer Based on Adaptive Control techniques"- *IEEE Transaction on Power Apparatus and System*, Vol. PAS- **103**, No.8, August 1984.
- [2]. A M D Ferreira, J A L Barreiros and J R Brito-de-Souza, "Fuzzy Power Pystem Stabilizer including a Fuzzy PI Controller", *UKACC International Conference on Control, IEE*, Sept 1998.
- [3]. C.L.Chen and Y.Y.Hsu, " Coordinated Synthesis of Multi Machine Power System Stabilizer using an Efficient Decentralized Modal Control Algorithm"-*IEEE Transaction of Power System*, Vol. **2**, No.3, August 1987.
- [4]. G. Kanniah, O.Q. Malik and G.S. Hope, "Excitation Control of Synchronous Generator using Adaptive Regulators-part1: Theory and Simulation Results"- *IEEE Transaction on Power Apparatus and System*, Vol. PAS- **103**, No.5, May 1984.
- [5]. G V Moodley, G D Jennings, R G Harley and M T Wishart, "Fuzzy Logic Power System Stabilizer in Multi Machine Stability Studies" *IEEE AFRICON*, pp. 843-848, Sept. 1996.
- [6]. H.A.Moussa, Y.Yu, "Optical Power System Stabilization Through Excitation and/or Governor Control"- *IEEE Transaction on Power Apparatus and System*, Vol. PAS- **91**, pp1166-1174, 1972.
- [7]. H.Y.Altavlib, P.C. Krause, "Dyanamic Equivalent by Combination of Reduced Order Models of System Components"- *IEEE Transaction on Power Apparatus and System*, Vol. PAS- **95**, No.5, Sept./Oct 1976.
- [8]. Jaun, L H Herron and A Kalam, "Comparison of Fuzzy Logic Based and Rule Based Power System Stabilizer", *IEEE Conference*

- on Control Application, pp.692- 697, sept.1992.
- [9]. P. Kundur, D.C. Lee, H.M. Zein El-Din, "Power System Stabilizer for Thermal Units: Analytical Techniques and on Side Validation" - *IEEE Transaction on Power Apparatus and System*, Vol. PAS- **100**, No.1, Jan 1981.
- [10]. Q.H. Li, D.Z. Zhao and Y.Y. Yu, "A New Pole Placement Method for Excitation Control Design to Damp SSR of Non Identical Two Machine System" - *IEEE Transaction on Power System*, Vol. **4**, No.3, August 1989.
- [11]. R Gupta, D K Sambariya and R Gunjan, "Fuzzy Logic Based Robust Power System Stabilizer for a Multi-machine Power System", *IEEE ICIT*, pp. 1037-1042, Dec 2006.
- [12]. R.J. Fleming and J. Sun, "An Optimal Multi Variable Stabilizer for a Multi-Machine plant" - *IEEE Transection on energy conversions*, Vol. **5**, No.1, March 1990.
- [13]. R.V. Larsen and D.A. Suann, "Appling Power System Stabilizer" – In three parts, *IEEE Transaction on Power Apparatus and System*, Vol. PAS- **100**, No.6, June 1981.
- [14]. S. Cheng, Y.S. Chow, O.P. Malik and G.S. Hope, "An Adaptive Synchronous Machine Stabilizer" - *IEEE Transaction on Power Apparatus and System*, Vol. PWRS- **1**, No.3, August 1986.
- [15]. S. Majid, H A Rahman and O B Jais, "Study of Fuzzy Logic Power System Stabilizer", *IEEE Student Conference on Research and Development 2002*, pp. 335-339.
- [16]. Y.N. Yu and C. Siggers, "Stabilization and Optimal Control Signal for a Power System" - *IEEE TP-531 summer power meeting and EHV conference*, July 1970.
- [17]. V. Arcidiacono, E. Ferrari, R. Marconato, J. Dos Ghali, D. Grandez, "Evaluation and Improvement of Electromechanical Oscillation Damping by Means of Eigen value-Eigenvector – Analysis & Practical result in the Central per unit Power System" - *IEEE Transaction on Power Apparatus and System*, Vol. PAS- **100**, No.1, Jan 1981.

